

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

October 22, 2008

ACORN ENGINEERING COMPANY FARHAD SHAHRIARY 15125 PROCTOR AVE CITY OF INDUSTRY CA 91746

Re: Description: HEALTH CARE PLUMBING APPLIANCE Manufacturer: ACORN ENGINEERING COMPANY

Product Name: SWIVETTE(CAREWARE)

Model Number(s): 4010, 4012, 4015, 4020, 4022, 4025, 4030, 4032 AND 4035

Product File No: 20080484

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2014.

This approval is contingent upon compliance with the following stipulation(s):

• Installation of this product must include the optional anti-siphon pressure type vacuum breaker serving the bed pan washer. The anti-siphon pressure type vacuum breaker must be listed by a nationally recognized listing agency as conforming to ASSE Standard 1056. Specific plan approval from the department must be obtained for the installation of the anti-siphon pressure type vacuum breaker in health care and related facilities.

This approval supersedes the approval issued on February 7, 2003 under product file number 20030610.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030610.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely.

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742 Fax: 608-267-9566

E-mail: Jerry.Thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 08048406.DOC